29/10/2013 www.crouzet.com



LN plug-in emptying function LN Part number 84870304




- Relay for controlling level of conductive liquids
- Regulation of two levels :
- minimum
- maximum
- Empty function
- Plug in (8 or 11 pins)
- Sensitivity adjustable from 5 kΩ to 100 kΩ

D٥	r4	nı	ım	he	T C

Туре	Supply voltage	Base
84 870 304 LN	230 V AC	8-pin

Specifications

Supply voltage Un	230 V, 110 V, 48 V, 24 V AC, 50/60 Hz
Operating range	0,85 →1,15 x Un
Max. absorbed power	3 VA
Adjustable sensitivity	5 kΩ→100 kΩ
Measurement accuracy (at maximum sensitivity)	0 →+30 %
Electrode voltage (max)	24 V AC (50/60 Hz)
Electrode current (maximum)	1 mA (50/60 Hz)
Maximum cable capacity	10 nF
Response time high level	300 ms
Response time low level	500 ms
Output relay (according to AC1 resistive load)	1 AgCdO switch 8 A AC max.
Galvanic isolation via transformer (4 kV, 8 mm creepage distance)	Class II
Isolation of contacts and electrodes from power supply	2,5 kV AC
Operating temperature range (°C)	-20 →+60
Storage temperature range (°C)	-30 →+70
Weight (g)	140



Operating principle

Control of maximum and/or minimum levels of conductive liquids (tap water, sea water, waste water, chemical solutions, coffee etc).

The principle is based on measurement of the apparent resistance of the liquid between two submerged probes. When this value is lower than the preset threshold on the unit front face, the output relay changes state. To avoid electrolytic phenomena, an AC current funs across the probes. Applications found in environmental, chemical industries and food technology etc.

Regulation of two levels: Minimum / Maximum


The output relay changes state when the level of liquid reaches the maximum electrode, with the minimum electrode submerged. It returns to its initial state when the minimum probe is no longer in contact with the liquid.


The probe wire (max length 100 metres) does not have to be screened, but avoid mounting it in parallel with the power supply wires. A screened wire can be used, with the screening connected to the common.

Nº	Legend
0	Max. level
②	Min. level

29/10/2013 www.crouzet.com

0	Output relay	
0	Down	
6	Unit power-up	
0	Controlled level	
0	Empty function	






TRADOS Empty Field

LN

29/10/2013 www.crouzet.com



N°	Legend
0	Input
0	Common
0	LN 11-pin
0	LN 8-pin